

Instructions for Riser Kits

P/N: 102367, 101975, 101976, 101977, 101978, 101979, 102364

Tools required:

- Electric drill
- 5/32" drill bit (carbide tip masonry bit if you have a concrete septic tank)
- #2 Phillips head driver bit

Steps:

- 1.) Expose and clean a 32" x 32" square area on the top of the septic tank centered on the clean-out opening on the tank.
- 2.) Apply the butyl sealant rope in the groove of the base plate (Fig. 1) on edge with the white tape towards the inside of the riser (Fig. 2), overlapping and kneading the ends of the rope together (Fig. 3).
- 3.) Remove the white tape from the sealant rope as discard the tape.
- 4.) Center the riser assembly on the tank clean-out opening and apply pressure around the perimeter of the base flange above the sealant rope to compress sealant between the tank and the base flange.
- 5.) Drill (4) 5/32" diameter holes through the dimples at the four corners of the base flange at least 1 ½" deep into the tank cover. If the tank in made of concrete, use a carbide tip masonry bit.
- 6.) Fasten the base plate to the tank using enclosed screws (Fig. 4).
- 7.) Backfill around riser with sand or washed stone to prevent movement from frost if applicable in your climate.




Figure 1



Figure 2

P/N: 102368

RFVA



Figure 3



Figure 4

Septic Tank Riser Assembly

Karl K. Holt President Aero-Stream, LLC January 7, 2015

RECEIVED

JAN 1 2 2015

SAFETY & BUL DINGS

Introduction

This approval request is for a family of septic tank riser assemblies ranging from a nominal 7" - 51" height. The construction of all risers is identical.

Specifications

- 1. Riser base manufactured of nominal ¼" thick HDPE and anchored to tank with mechanical fasteners.
- 2. Riser base sealed to tank with butyl joint sealant.
- 3. Riser ring manufactured of HDPE double wall corrugated pipe per ASTM F2648, 24" I.D.
- 4. Riser ring attached to riser base with minimum of (3) mechanical fasteners.
- Riser ring sealed to riser base with butyl, silicone or polyurethane joint sealant.
- 6. Secondary safety barrier fastened to I.D. of riser ring with minimum of (3) mechanical fasteners.
- 7. Secondary safety barrier can be removed to access tank for repair of baffles, etc. by loosening (3) mechanical fasteners.
- 8. Tank can be serviced without removal of secondary barrier by inserting hose through triangular openings.
- Riser cover manufactured of nominal 1/8" thick HDPE with capability of being filled with concrete or aggregate to increase mass.
- 10. Riser cover attached to riser ring with (4) mechanical fasteners which are not standard Phillips or flat slot drive to be considered an effective locking device.
- 11. Riser cover sealed to riser ring with closed cell foam gasket.
- 12. Riser cover to have raised molded-in text "WARNING DO NOT ENTER DANGEROUS GASES" or "DO NOT ENTER WITHOUT PROPER EQUIPMENT DANGEROUS GASES EXIST IN TANK".
- 13. Riser assembly tested under compressive load of 3,500 or 2,500 lbs resulting in 1.32" max. deflection (see attached 3rd party test results).
- 14. See chart below for model information.

Model	Nominal Height	Total Height
AS-R07	7	7.125
AS-R10	10	10.25
AS-R13	13	13.375
AS-R20	20	19.625
AS-R26	26	25.875
AS-R38	38	38.25
AS-R51	51	50.875

JAM 1 2 2015 SAFETY & BULDINGS

<u>Images</u>



Typical Riser Components



Warning Message



With Safety Barrier



51" Riser Assembly



7" Riser Assembly

W/Safety Barrier In-Place (Cover Not Shown)

I certify that the information contained in this report is accurate and meets or exceeds the requirements of product approval as outlined in WI Comm SPS 383.

Karl K Holt

President

Signature

1/7/15 Date

JAN 1 2 2015 SAFETY & BUILDINGS

